

Certificate of Compliance

Certificate Number **20070913-EX3971V1S7**
Report Reference **EX3971V1S7-20061111-20061110**
Issue Date **2007 September 13**

Page 1 of 1



Issued to: **Tornatech Inc**
#132, 7075 PLACE ROBERT-JONCAS
ST LAURENT, QC H4M 2Z2 CANADA


This is to certify that representative samples of **Fire Pump Controllers**
Fire Pump Controllers, Models GPA, GPP, GPR, GPS, GPV, GPY, and GPW.
Transfer Switches, Models GPG and GPU.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **UL 218, Fire Pump Controllers**
CAN/CSA C22.2 No. 14 Industrial Control Equipment
NFPA 20, Stationary Pumps for Fire Protection

Additional Information: **See File EX3971 Volume 1 Section 7, Issued 20061111, or UL On-Line Certification Directory for ratings.**

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: **Jeff Zwieschowski**

Jeff Zwieschowski, Senior Project Engineer

Underwriters Laboratories Inc.

Reviewed by: **Timothy Lueck**

Timothy Lueck, Staff Engineer

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions in The United States of America you may call 1-877-UL-HELPS.