

CERTIFICATE OF COMPLIANCE

Certificate Number E158750
Report Reference E158750-19940223
Issue Date 2023-SEPTEMBER-28

Issued to: TORNATECH INC
Listee Company: 4100 Desserte Sud, (A-440 Ouest)
Laval
QC
CA
H7T 0H3

Manufacturer Company: TORNATECH INC
4100 Desserte Sud, (A-440 Ouest)
Laval
QC
CA
H7T 0H3

**This is to certify that
representative samples of**

INDUSTRIAL CONTROL PANELS

USL, CNL: Industrial Control Panels.
Includes Jockey Pump Controller Models JP1, JP2, JP3, JPLT, JPV, JPY, JPD, DJP, and DJD; Remote Alarm Panel Models APE, APEE, APD, APDD, and APED; Low Level Lockout Panel Model LPL; and Low Suction Pressure Shutdown Panel Model LPS. These models are not exhaustive.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508A, 3RD Edition, Industrial Control Panels
CSA C22.2 No. 14, 13th Edition, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

