

# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX3971  
**Report Reference** EX3971-20030507  
**Issue Date** 2023-SEPTEMBER-27

**Issued to:** TORNATECH INC  
**Listee Company:** 4100 Desserte Sud, (A-440 Ouest)  
Laval  
QC  
CA  
H7T 0H3

**Manufacturer Company:** Tornatech FZE  
Warehouse CC04 R/A08  
PO Box 18435  
Jebel Ali  
Dubai  
AE

**This is to certify that representative samples of** PUMP CONTROLLERS, FIRE  
PRODUCT COVERED: USL, CNL - Model GPD Series controller for engine-driven centrifugal fire pumps.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 218 / CSA C22.2 No. 263-15, Fire Pump Controllers, 3rd / 2nd Edition  
UL 508, Industrial Control Equipment, 18th Edition  
NFPA 20, Standard for the Installation of Stationary Pumps for Fire Protection

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

