

CERTIFICATE OF COMPLIANCE

Certificate Number 20140708-EX3971
Report Reference EX3971-20030507
Issue Date 2014-JULY-08

Issued to: TORNATECH INC
132
7075 PLACE ROBERT-JONCAS
ST LAURENT
QC H4M 2Z2 CANADA


This is to certify that representative samples of PUMP CONTROLLERS, FIRE
GPD Series controller for engine-driven centrifugal fire pumps

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL218, Fire Pump Controllers
UL508, Industrial Control Equipment
CSA C22.2 No. 263-09, Fire Pump Controllers
CAN/CSA C22.2 No. 14-13, Industrial Control Equipment
NFPA20 (2010), Installation of Stationary Pumps for Fire Protection

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

