

CERTIFICATE OF COMPLIANCE

Certificate Number 20171018 – EX3971
Report Reference EX3971 – 20030507
Issue Date 2017-OCTOBER-18

Issued to: TORNATECH INC
#132
7075 PLACE ROBERT-JONCAS
ST LAURENT, QC H4M 2Z2 CANADA

Manufacturer Company: TORNATECH EUROPE SPRL
Avenue Vesale 32A
1300 Wavre BELGIUM

This is to certify that representative samples of Pump Controllers, Fire
GPD Series controller for engine-driven centrifugal fire pumps
Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 508, "Industrial Control Equipment,"
ANSI/UL 218, "Fire Pump Controllers," CSA-C22.2 No. 263, "Fire
Pump Controllers" and ANSI/NFPA 20, "Installation of Stationary
Pumps for Fire Protection."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

