

CERTIFICATE OF COMPLIANCE

Certificate Number 20171019– E158750
Report Reference E158750 – 19940223
Issue Date 2017-OCTOBER-19

Issued to: TORNATECH INC
#132
7075 PLACE ROBERT-JONCAS
ST LAURENT, QC H4M 2Z2 CANADA

Manufacturer Company: TORNATECH EUROPE SPRL
Avenue Vesale 32A
1300 Wavre BELGIUM

This is to certify that representative samples of Industrial Control Panels
Includes jockey pump controller Model JP, remote alarm panel for electric fire pump controllers Model APE, remote alarm panel for diesel engine fire pump controllers Model APD, and low pressure shutdown panel Model LPS. These models are not exhaustive.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508, Industrial Control Panels.
CSA C22.2 NO. 14-13, Industrial Control Equipment.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

