



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP-0454

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Tornatech, Inc.

Manufacturer's Technical Representative: Felix Turcotte

Mailing Address: 7075 Pl. Robert-Joncas #132, Saint-Laurent, QC H4M 2Z2

Telephone: (514) 334-2503

Email: felixt@tornatech.com

Product Information

Product Name: Electrical Control Panels on Life Safety/Critical Branch

Product Type: Fire Protection & Security Panels

Product Model Number: Varies, see attachment.

General Description: Electric and diesel fire pump controllers with various subcomponents with carbon or stainless enclosures.

Mounting Description: Rigid base/wall and Rigid wall mounted

Tested Seismic Enhancements: None

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.


Contact Person: Galen Reid

Mailing Address: 5215 Hellyer Ave. Suite 210, San Jose, CA 95138

Telephone: (541) 604-7225

Email: greid@structint.com

Title: Manager, TRU Compliance





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.
Name: Andrew Coughlin California License Number: S6082
Mailing Address: 5215 Hellyer Ave, Suite 101, San Jose, CA 95138-1025
Telephone: (415) 635-8461 Email: acoughlin@structint.com


Certification Method

GR-63-Core ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3
 Other (Please Specify): _____

Testing Laboratory

Company Name: CLARK TESTING LABORATORY, INC.
Contact Person: Russell Matich
Mailing Address: 1801 Route 51, Jefferson Hills PA 15025
Telephone: (412) 387-1004 Email: rmatich@clarktesting.com

Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)
Contact Person: Jeremy Lange
Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513
Telephone: (972) 247-9657 Email: Jeremy@etldallas.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) =	1.50 (SDS = 2.00); 1.44 (SDS = 3.20)
SDS (Design spectral response acceleration at short period, g) =	2.0 (z/h = 1.0); 3.2 (z/h = 0.0)
a_p (Amplification factor) =	2.5
R_p (Response modification factor) =	6.0
Ω_0 (System overstrength factor) =	2.0
I_p (Importance factor) =	1.5
z/h (Height ratio factor) =	1 and 0
Natural frequencies (Hz) =	See Attachment
Overall dimensions and weight =	See Attachment

OSHPD Approval (For Office Use Only) - Approval Expires on 12/31/2025

Date:	9/3/2021	
Name:	Mohammad Karim	Title: Supervisor, Health Facilities
Special Seismic Certification Valid Up to: SDS (g) =	See Above	z/h = See Above
Condition of Approval (if applicable):		

