

CERTIFICATE OF COMPLIANCE

Certificate Number EX3971
Report Reference EX3971-20030507
Issue Date 2022-MARCH-07

Issued to: TORNATECH INC
Listee Company: 4100 Desserte Sud, (A-440 Ouest)
Laval
QC H7T 0H3 CANADA

Manufacturer Company: TORNATECH FZE
WAREHOUSE NO RA08CC04
JEBEL ALI FREE ZONE
DUBAI UNITED ARAB EMIRATES

This is to certify that representative samples of PUMP CONTROLLERS, FIRE
Model GPD Series controller for engine-driven centrifugal fire pumps.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 218 / CSA C22.2 No. 263-15, Fire Pump Controllers
UL 508, Industrial Control Equipment
NFPA 20, Installation of Stationary Pumps for Fire Protection

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

