

CERTIFICATE OF COMPLIANCE

Certificate Number EX3971
Report Reference EX3971-2006-11-11
Date 2022-August-17

Issued to: TORNATECH INC
4100 Desserte Sud, (A-440 Ouest)
Laval QC H7T 0H3 CA

This is to certify that representative samples of PUMP CONTROLLERS, FIRE
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 218 / CSA C22.2 No. 263-15, Fire Pump Controllers, UL 508, Industrial Control Equipment, and NFPA 20, Installation of Stationary Pumps for Fire Protection

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX3971
Report Reference EX3971-2006-11-11
Date 2022-August-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Horsepower rated, Models GPA, GPP, GPR, GPS, GPV, GPY, or GPW; may be followed by a number 110 through 575 with - or /; followed by a number 200 through 600 with /; followed by a number 1 through 500 with /; followed by 1 or 3 with /; followed by 50 or 60 or 50/60.

Kilowatt rated, Models GPA, GPP, GPR, GPS, GPV, GPY, or GPW; followed by -400/; followed by a number 0.75 through 560 with kW/; followed by 3 with /; followed by 50 or 60 or 50/60

Transfer Switches, horsepower rated, Models GPU; may be followed by a number 110 through 575 with - or /; followed by a number 200 through 600 with /; followed by a number 1 through 500 with /; followed by 1 or 3 with /; followed by 50 or 60 or 50/60.


Transfer Switches, kilowatt rated, Models GPU; followed by -400/; followed by a number 0.75 through 560 with kW/; followed by 3 with /; followed by 50 or 60 or 50/60

Limited Service Fire Pump Controllers, horsepower rated, Models GPL; may be followed by a number 110 through 575 with - or /; followed by a number 200 through 600 with /; followed by a number 1 through 30 with /; followed by 1 or 3 with /; followed by 50 or 60 or 50/60.

Limited Service Fire Pump Controllers, kilowatt rated, Models GPL; followed by -400/; followed by a number 0.75 through 22 with kW/; followed by 1 or 3 with /; followed by 50 or 60 or 50/60

Limited Service Transfer Switches, for connection to a second utility, horsepower rated, Models GLU; may be followed by a number 110 through 575 with - or /; followed by a number 200 through 600 with /; followed by a number 1 through 30 with /; followed by 1 or 3 with /; followed by 50 or 60 or 50/60.

Limited Service Transfer Switches, for connection to a second utility, kilowatt rated, Models GLU; followed by -400/; followed by a number 0.75 through 22 with kW/; followed by 1 or 3 with /; followed by 50 or 60 or 50/60



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

