

# CERTIFICATE OF COMPLIANCE

**Certificate Number** EX15018  
**Report Reference** EX15018-20141224  
**Issue Date** 2022-SEPTEMBER-01

**Issued to:** TORNATECH INC  
4100 Desserte Sud, (A-440 Ouest)  
Laval  
QC  
CA  
H7T 0H3

**This is to certify that  
representative samples of**

PUMP CONTROLLERS, FIRE, OVER 600 VOLTS  
Medium Voltage Fire Pumps Controllers model MPA,  
followed by 2300, 3300, 4160, 4500, 7200, followed by 100  
to 3000, followed by 3, followed by 60, and may be followed  
by additional letters and numbers.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 218 and CSA C22.2 No. 263-09, Fire Pump Controllers.  
UL 347 and CSA C22.2 No. 253-09, Medium-Voltage AC  
Contactors, Controllers, and Control Centers.  
CSA C22.2 No. 14-13, Industrial Control Equipment.  
NFPA 20, Installation of Stationary Pumps for Fire  
Protection.

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

