

Certificate of Compliance

Issued to:

Tornatech FZE

PO Box 18435

Plot No S10131, Jebel Ali South

Dubai AE

TORNATECH INC

4100 Desserte Sud, (A-440 Ouest)

Laval

QC

CA

H7T 0H3

Certificate Number:

EX3971

Report Reference:

EX3971-20030507

Issue Date:

2024-04-03

This certificate confirms that representative samples of:

Please see the addendum for additional Product Information.

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

Please see the addendum for Standards of Safety.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch

UL Mark Certification Program Owner

Certificate of Compliance

Certificate Number: EX3971
Report Reference: EX3971-20030507
Issue Date: 2024-04-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum:

Product Covered:

USL, CNL - Model GPD Series controller for engine-driven centrifugal fire pumps.

Standards for Safety:

UL 218 / CSA C22.2 No. 263-15, Fire Pump Controllers, 3rd / 2nd Edition

UL 508, Industrial Control Equipment, 3rd Edition

NFPA 20, Standard for the Installation of Stationary Pumps for Fire Protection